

TOWN OF SPRINGERVILLE WATER SYSTEM DISTRIBUTED CONTROL SYSTEM

ADDENDUM NO. 4

FEBRUARY, 2016

The Construction Documents for the Town of Springerville Water System Distributed Control System are hereby supplemented in the following particulars. All other provisions of the Construction Documents remain unchanged.

1. Bidders are advised that the project requirements include furnishing and installing 12 RTU's and two PLC panels.
2. Power may not be available at the West Side Tank. Bidders should base their bids on installing a new service and rack to mount the PLC.
3. Bidder's attention is directed to Note 2 on Sheet E-003 which states "Contractor to provide and install a control power transformer in the motor starter where the well site does not have 120V control power available."
4. Bidders are advised that a 4-inch diameter fitting will be available to install the ultrasonic level transducer on the East Side Tank.
5. Bidders are advised that the ultrasonic level transducer must be capable of submersed operation.

Please acknowledge receipt of this addendum on the Bid Form.

End of Addendum No. 4

